

FIREWORKS SEASONAL RETAILER INSPECTION SURVEY

PRINT ALL INFORMATION

NAME OF BUSINESS		FIREWORKS PERMIT NUMBER
ADDRESS OF BUSINESS		PHONE
CITY, STATE, ZIP		COUNTY
CONTACT NAME		PHONE
INSPECTION DATE	<input type="checkbox"/> RE-INSPECTION <input type="checkbox"/> REQUIRED	RE-INSPECTION DATE

LIST ITEM NUMBER REQUIRING CORRECTION USE REVERSE SIDE FOR EXPLANATION OF PROBLEM AREAS	Initial Inspection		Re-Inspection	
	APPROVED	LIST # NOT APPROVED	APPROVED	LIST # NOT APPROVED
VALID PERMIT AND DISPLAY OF PERMIT: Permit must be displayed in the holder's place of business				
TYPE OF FIREWORKS: Only Consumer fireworks UN0336, 1.4G permitted				
FIRE EXTINGUISHERS: 1. Minimum of 2 (2A minimum), at least one pressurized water type 2. Location of less than 200 Sq. Ft.: minimum of 1 (2A minimum) 3. Maximum travel distance to an extinguisher: 35 feet 4. All in accessible locations 5. Employees trained in extinguisher operation				
SITE REQUIREMENTS: 1. Certificate or other evidence verifying tent fabric as fire retardant treated 2. No hay, straw, or shavings unless flame retardant treated 3. 30' area around site clear of dry grass, dry brush, & combustible debris 4. Fireworks not displayed behind glass in direct sunlight 5. Fireworks out of public reach when attendant not on duty 6. No parking within 10' of sales location 7. No storage trailer within 10' of sales location 8. 20' from other building, other sales locations, cooking equipment, & generators 9. 50' from gasoline pumps, filling stations, propane dispensing, & storage tanks				
FIREWORKS DISCHARGE: 1. Fireworks shall not be discharged within 100' 2. At least one sign with 4" letters at each entrance: "NO FIREWORKS DISCHARGE WITHIN 100 FEET"				
NO SMOKING SIGNS: 1. At least 1 sign with 4" letters at each entrance: "FIREWORKS NO SMOKING" 2. No smoking in or within 25' of sales area				
MEANS OF EGRESS: 1. Minimum of 2 remote means of egress free of obstructions 2. Minimum clear aisle width not less than 48" 3. Tent exit opening not less than 44" in clear width 4. All fireworks not within 2' of any entrance or exit				
EMERGENCY LIGHTING AND EXIT SIGNS: 1. Exit signs to be self-luminous or illuminated (required if open for business after dark) 2. Emergency lighting required in sales areas of 800 sq. ft or greater (not required if not open after dusk)				
ELECTRICAL EQUIPMENT: 1. Electrical system & equipment isolated from the public 2. All electrical wiring & equipment UL approved, installed and maintained to prevent electrical hazards (in trenches or protected by approved covers) 3. Branch circuits protected by GFCI (if susceptible to water exposure)				
PROHIBITED ACTIVITY/ITEMS: 1. Persons under 16 years prohibited from selling or working unless under the supervision of another at least 18 years of age 2. Storage & display of pest control devices prohibited 3. Electronic pest control devices prohibited inside sales location 4. Alcoholic beverages prohibited during business hours 5. Proximate & display fireworks not sold with 1.4G fireworks				

BUSINESS REPRESENTATIVE RECEIVING INSPECTION FORM:

PRINT NAME: _____ SIGNATURE: _____

INSPECTION CONDUCTED BY:

PRINT NAME: _____ SIGNATURE: _____